

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-1574:127

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield NJ 07004-1561
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942

DESIGN: Models 5951ADT and 5951RADT (fixed temperature) electronic heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 135⁰ F fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as heat detectors for use with Notifier Models B501 or B710LP base (CSFM Listing No. 7300-0028:173) and separately listed compatible fire alarm control units. Refer to listee's Installation Instructions Manual for details.

XLf: 7270-0028:196

3-07-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MARCH 7, 2003

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager